




Net drawdown does not exceed the drawdown allowance of 2.0 ft for any well within 1 mile of the proposed location. Therefore, critical well analysis is not necessary.

**Conclusion:**

The proposed move is likely to create minimal effects on neighboring wells and appears unlikely to cause impairment. Any concerned neighbors should contact GMD3 at (620) 275-7147 or the Division of Water Resources at (620) 276-2901.



WELL TEST ANALYSIS

Data Set: C:\Users\trevora\Documents\2022\_moves\6389\6389 Current.aqt  
 Date: 08/05/22 Time: 11:48:02

PROJECT INFORMATION

Company: GMD 3  
 Project: 6389  
 Location: Grant County


WELL DATA

Pumping Wells

Observation Wells

Well Name	X (ft)	Y (ft)
6389	-117211	269865

Well Name	X (ft)	Y (ft)
□	-117211	269865



WELL TEST ANALYSIS

Data Set: C:\Users\trevora\Documents\2022\_moves\6389\6389 Proposed.aqt

Date: 08/05/22

Time: 11:47:54

PROJECT INFORMATION

Company: GMD 3

Project: 6389

Location: Grant County

WELL DATA

Pumping Wells

Observation Wells

Well Name	X (ft)	Y (ft)
6389	-115955	268923

Well Name	X (ft)	Y (ft)
□	-115955	268923