



10889 & 24931: Drawdown from current location = 0.95 ft  
Drawdown from proposed location = 3.24 ft  
Net drawdown = **2.3 ft**

17498: Drawdown from current location = 1.72 ft  
Drawdown from proposed location = 4.07 ft  
Net drawdown = **2.3 ft**

Domestic 10-33-38: Drawdown from current location = 0.90 ft  
Drawdown from proposed location = 3.09 ft  
Net drawdown = **2.2 ft**

Domestic 16-33-38: Drawdown from current location = 3.53 ft  
Drawdown from proposed location = 3.02 ft  
Net drawdown = **-0.5 ft**


Domestic 15-33-38: Drawdown from current location = 1.02 ft  
Drawdown from proposed location = 3.80 ft  
Net drawdown = **2.8 ft**

Domestic 21-33-38: Drawdown from current location = 3.12 ft  
Drawdown from proposed location = 2.90 ft  
Net drawdown = **-0.2 ft**

Net drawdown does not exceed the drawdown allowance of 4.0 ft for any well within 1 mile of the proposed location. Therefore, critical well analysis is not necessary.

**Conclusion:**

The proposed move is likely to create minimal effects on neighboring wells and appears unlikely to cause impairment. Any concerned neighbors should contact GMD3 at (620) 275-7147 or the Division of Water Resources at (620) 276-2901.



WELL TEST ANALYSIS

Data Set: C:\Users\trevora\Documents\2023\_moves\968\_8210\_15366\968 Current.aqt  
 Date: 01/24/23 Time: 16:26:44

PROJECT INFORMATION

Company: GMD 3  
 Project: 968\_8210\_15366  
 Location: Stevens County


WELL DATA

Pumping Wells

Observation Wells

Well Name	X (ft)	Y (ft)
968 & 8210	-192177	108587

Well Name	X (ft)	Y (ft)
□	-192177	108587



WELL TEST ANALYSIS

Data Set: C:\Users\trevora\Documents\2023\_moves\968\_8210\_15366\968 Proposed.aqt  
 Date: 01/24/23 Time: 16:26:38

PROJECT INFORMATION

Company: GMD 3  
 Project: 968\_8210\_15366  
 Location: Stevens County

WELL DATA

Pumping Wells

Observation Wells

Well Name	X (ft)	Y (ft)
968 & 8210	-188894	110898

Well Name	X (ft)	Y (ft)
□	-188894	110898